

From: <hans.krattiger@us.abb.com>
To: <JON-C@ipsc.com>
Date: 8/25/2003 12:23:15 PM
Subject: Re: Intermountain Power Drive Drawings - set 1

Hello Jon,

The drawings and pictures arrived well. Thanks, this helped us a lot to get us started last Friday already.

I have a few questions which you may be able to help me with:

1. What is the minimal short circuit capacity of the 6.9 kV bus? E.g. what is the power and impedance of the unit aux. transformer? This info is not on the provided drawings.
2. What are the subtransient reactances of the existing Westinghouse motors? This info is not on the provided drawings.
3. What are the physical access limitations on the mezzanine floor? E.g. door with and height.

I will call you to discuss.

Best regards
Hansueli Krattiger

Mgr. ABB Large AC Drives